

# ਦਫ਼ਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ, ਉਪ ਮੰਡਲ ਨੰ. 1, ਫਰੀਦਕੋਟ

ਵੱਲ,

ਬੁਰਸ ਮਾਤਾ ਗੁਜਰੀ ਪਬਲਿਕ ਸੀਨੀਅਰ ਸੈਕੰਡਰੀ ਸਕੂਲ,  
ਵੀ.ਪੀ.ਓ.ਸਾਦਿਕ, ਫਰੀਦਕੋਟ।


ਨੰ: 370

ਮਿਤੀ: 31-05-2023

ਵਿਸ਼ਾ:-

ਸਕੂਲ ਦੇ ਪੀਣ ਵਾਲੇ ਪਾਣੀ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਦੇ ਸਬੰਧ ਵਿੱਚ ਇਸ ਦਫ਼ਤਰ ਦੇ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਪਾਣੀ  
ਦਾ ਸੈਂਪਲ ਇਕੱਤਰ ਕਰਨ ਉਪਰੰਤ ਅਤੇ ਇਸ ਦਫ਼ਤਰ ਦੇ ਲੈਬ ਕੈਮਿਸਟ ਤੋਂ ਪਾਣੀ ਦਾ ਨਮੂਨਾ  
(ਸੈਂਪਲ) ਚੈਕ ਕਰਨ ਉਪਰੰਤ ਵੱਲੋਂ ਪੇਸ਼ ਕੀਤੀ ਰਿਪੋਰਟ ਅਨੁਸਾਰ ਪਾਣੀ ਦਾ ਸੈਂਪਲ ਪੀਣ ਯੋਗ  
ਪਾਇਆ ਗਿਆ ਹੈ। ਮੈਂ ਇਸ ਲਈ ਇਹ ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹਾਂ ਕਿ ਤੁਹਾਡੇ ਸਕੂਲ ਦਾ ਪਾਣੀ  
ਪੀਣ ਯੋਗ ਅਤੇ ਸਹੀ ਹੈ।



ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ:1,  
ਫਰੀਦਕੋਟ।

## DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chowk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com

To,

DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL  
DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL, SADIQ

No.: DWTL/FDK/2324/00030 Dated : 29/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Letter Ref.DMG/005/2023 Dated: 22/05/2023

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 25/05/2023. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



**Authorized Signatory**  
**For, District water Testing Laboratory,**  
**Faridkot**



**TEST REPORT**

Name & Address of Customer : <b>DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL</b> <b>DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL, SADIQ</b>	Customer Reference No.	No : Letter Ref.DMG/005/2023 Dated : <b>22/05/2023</b>
	Sample Submitted by	<b>LAKHWINDER SINGH</b>
	Date of Sample Receipt	<b>25/05/2023</b>
	Analysis Starting Date	<b>26/05/2023</b>
	Analysis completion Date	<b>27/05/2023</b>

Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	<b>TC103942300000086F</b>	Sample Type :	<b>Water</b>
Test Report No.:	<b>DWTL/FDK/2324/00030</b>	Date of Issue :	<b>29/05/2023</b>
Registration no.:	<b>DWTL/FDK/REG2324/00075</b>	Condition of Sample :	<b>Sealed</b>
Collection Point:	<b>R/o Water</b>	Quantity/Type of Bottle:	<b>1000 ml / Plastic Bottles</b>
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL, SADIQ R/o / NA</b>
Village :	<b>Sadiq</b>	Habitation :	<b>Sadiq</b>
Block:	<b>Faridkot</b>	District :	<b>Faridkot</b>
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.80	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	170	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	44	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	40	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	8	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	4	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method

# DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com



11	Chloride	44	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit:  $25 \pm 5^\circ\text{C}$  and Humidity condition limit:  $50 \pm 20\%$

**Vishal Kumar**  
**Chemist/Analyst**  
**Authorized Signatory**  
**For, District water Testing Laboratory,**  
**Faridkot**

----- End of the Test Report -----



# DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanalya Chowk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com

## INVOICE

Date : 29/05/2023

No. : INV/2324/00036

DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL  
DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL SADIQ

Letter No. 005 Dt. 22/05/2023

Sample Receiving No. DWTL/FDK/R2324/00036 Dt. 29/05/2023

Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
Sadiq, DIVINE MATA GUJRI PUBLIC SENIOR SECONDARY SCHOOL SADIQ	Water	Private Schools	Basic Chemical : pH, Colour, Odour, Taste, TDS, Turbidity, Alkalinity, Hardness, Calcium, Magnesium, Chloride	1	130.00	130.00
Total						130.00

One Hundred Thirty Only.

Payment Status : PAID

STR No. : NA

Payment Mode : Cash

Note:- \* Discount applicable as per Government Notification Number : No 9284 & Date : 09/11/2021

Authorised Signatory

